



REMOVE EXISTING BUSWAY. SEE GENERAL NOTE #13, DWG E-1.

* BOTTOM OF SLAB 30" TO TOP OF LOWER BUSWAY. DROPPED BEAMS NOT SHOWN (LOWER THAN SLAB).

"UPPER BUSWAY 13 1/2" AFF TOP.

3.5" CONDUITS

11.5'

3"

12.2'

10.4'

12.6' AFF TO BOT.) (13 1/2" AFF TO TOP).

LOWER 1600A BUSWAY

22' CLEAR

30' CLEAR

(2) 90° OFFSET

SWITCHBOARD R

SWITCHBOARD L

T

T

T

T

FRONT 7'-0"

EXISTING TRANSFORMER 1500KVA, 13.8KV-480/277V (TYPICAL).

EXISTING 480/277V SWITCHBOARD (TYP).

SHAFT

41st FLOOR